

Er.P.SIVAKUMAR, B.E, M.Sc (Valuation), M.I.E,F.I.V.,
Class IA Registered Engineer Collectorate of Cuddalore District,
Chartered Civil Engineer (M-146885-5)

80, Lawrence Road (Hotel Pallava Upstair), Cuddalore -2, Cell : 93676 20365, E-mail: vr.siva@yahoo.com

STABILITY CERTIFICATE



NAME OF THE APPLICANT : V.C.S. SHEMFORD INTERNATIONAL SCHOOL
(Run by Veechidambaranar Educational Trust)

LOCATION OF THE BUILDING : R.S.No: 5/8, 5/9, 5/11 & 6/1, Vellakarai Road,
Vettukulam Village, Cuddalore Taluk & District.

Er.P.SIVAKUMAR, B.E, M.Sc (Valuation), M.I.E,F.I.V.,
Chartered Civil Engineer (M-146885-5)
Approved Valuer, Class IA Registered Engineer
Collectorate of Cuddalore District.

Off : 80, Lawrence Road,
Cuddalore - 607 002
04142 - 223365
Cell : 93676 20365

Ref.No-29/ST/2026

Date : 01.08.2026

TO WHOMSOEVER IT MAY CONCERN

STABILITY CERTIFICATE

The Existing Building of R.C.C. Framed column structure for the “V.C.S. Shemford International School” (Run by Veechidambaranar Educational Trust) in R.S.No: 5/8,5/9,5/11 & 6/1, Vellakarai Road, Vettukulam Village, Cuddalore Taluk & District is stable in structural as per the design analysis.

- *The structure is R.C.C.Framed Column structure.*
- *The soil type is Red Soil with SBC of about 150 KN/m²*
- *The depth of foundation being 1.83m, the Column Footings rest on firm Soil Strata.*
- *The materials used for construction were adequate quality with Indian Standard codes, with proper curing, compaction and consolidation as and Necessary.*
- *The construction drawings were referred too and found that the concrete mix, Reinforcement details, sizes and thickness are as standard Specifications with adhering quality.*
- *The terrains around the structure seem to assist free from run – off and Drain this avoiding water logging.*

With the above stated facts and details, it is confirmed and certified that the Existing R.C.C.framed wall structure will sagely withstand and bear Ground Floor and First Floor loadings as per specifications and strong enough to ensure structural stability.

Place : Cuddalore
Date : 01.08.2026


Signature of the Engineer,
Er. P. SIVAKUMAR, B.E., M.I.E., F.I.V.,
REGISTERED ENGINEER,
CLASS-IA (Under Tamil Nadu Public Building Act)
Reg. No: B1/18287/2017
No: 80, Lawrence Road,
CUDDALORE - 607 002.
Cell: 9367620365.

**STATEMENT TO ACCOMPANY THE CERTIFICATE OF
STRUCTURAL SOUNDNESS**

1. Location of the building
(Door No, street Name
& Name of the Place) : *V.C.S. Shemford International School
(Run by Veechidambaranar Educational Trust)
R.S.No: 5/8,5/9,5/11 & 6/1, Vellakarai Road,
Vettukulam Village, Cuddalore Taluk & District.*
2. Age of the Building : *17 Years*
3. Number of Store's : *Two Storied*
4. Short description of structures,
Steel R.C.C. Framed or load
bearing masonry : *R.C.C roof framed Structure*
5. Purpose for which the building
certified for use : *Class rooms, Office, Staff room, Computer room,
Library And Toilet*
6. The period for which the building
will be structurally sound : *03.08.2026 to 02.08.2029*
7. Number of persons to be
Accommodated : *500 Nos*
8. Remarks : *Nil*

Date: *01.08.2026*


Signature of the Engineer

Er. P. SIVAKUMAR, B.E., MIE., FIV.,
REGISTERED ENGINEER,
CLASS-IA (Under Tamil Nadu Public Building Act)
Reg. No: B1/18287/2017
No: 80, Lawrence Road,
CUDDALORE - 607 002.
Cell: 9367620365.

STATEMENT ACCOMPANYING
FORM - A

1. Door No. of the building : *V.C.S. Shemford International School*
Location (street name, ward no) : *(Run by Veechidambaranar Educational Trust)*
Name of place i.e.corporation/ : *R.S.No: 5/8,5/9,5/11 & 6/1, Vellakarai Road,*
Municipality/ Panchayat/ : *Vettukulam Village, Cuddalore Taluk & District.*
Cantonment, etc,
- 2 Year of construction : *2009*
- 3 Approximate cost of : *Rs.2,20,00,000/-(Rupees Two Crore Twenty Lakhs*
construction as per current rates : *Only)*
4. Purpose for which the building : *Class rooms, Office, Staff room, Computer room,*
is being used or proposed to be used : *Library And Toilet*
5. Purpose for which the building : *-do-*
etc either been used
6. Detailed of construction of the : *R.C.C. Roof Building*
Building
 - a) Foundation : *R.C.C Footings*
 - b) Basement : *Brick Masonry with Cement mortar*
 - c) Superstructure : *Brick Masonry with cement mortar*
 - d) Floor & Roof : *Vitrified Tiles Flooring, R.C.C roof*
 - e) Area of the Building :
Ground Floor – 9993.35 Sq.ft (or) 928.75Sq.m
Portico - 614.72Sq.ft (or) 57.13Sq.m
First Floor – 10608.07 Sq.ft (or) 985.88Sq.m

7. Period for which license is Required : 03.08.2026 to 02.08.2029
8. Number of person to be Accommodated : 500 Nos

Certified that no addition or alteration has been made to the existing building or portion of a building for which this application has been made. I undertake to obtain a fresh license in case any addition or alteration is made to the existing building. I also undertake to obtain a fresh license if the purpose for which the license was granted for the use of the building or a portion of the building originally changed or altered subsequently.

Date : 01.08.2026

Signature of the owner of the Building

Date : 01.08.2026


Signature of the Registered Engineer

Er. P. SIVAKUMAR, B.E., M.I.E., F.I.V.,
REGISTERED ENGINEER,
CLASS-IA (Under Tamil Nadu Public Building Act)
Reg. No: B1/18287/2017
No: 80, Lawrence Road,
CUDDALORE - 607 002.
Cell: 9367620365.

FORM - B

(Form of certificate of structural soundness under sub section (4) of the Tamil Nadu Public Building (Licensing) Act 1965 (Tamil Nadu 13 of 1965) referred to in rule 4 of the Tamil Nadu Public buildings (Licensing) (Rule 1966.)

I certify that I have inspected the site, mentioned in the statement and furnish below its salient technical features:-

I. Foundation

1. Depth below ground level : *1.83 M depth*
2. Nature of soil not with at Foundation level : *Red Soil*
3. Pressure at foundation : *75KN/m²*
4. Probable safe bearing capacity of the soil met with at foundation : *150KN/m²*

II. Super Structure:

1. Maximum stress in the most critical section of masonry & concrete : *Within permissible Limit*
2. Nature of masonry and concrete & it safe permissible stress : *Brick Masonry – 3.5N/mm²
Concrete M15 – 5.0N/mm²*

The structural soundness of the building has been verified by me with reference to I.S.I loading standards 878 (Latest Version) and other relevant Indian standards code of practice and I declare that the building is structurally sound to be used as public building for the purpose noted in the statement. A license may be granted for the period of **03.08.2026 to 02.08.2029**

Date : **01.08.2026**


Signature of the Engineer,

Er. P. SIVAKUMAR, B.E., M.I.E., F.I.V.,
REGISTERED ENGINEER,
CLASS-IA (Under Tamil Nadu Public Building Act)
Reg. No: B1/18287/2017
No: 80, Lawrence Road,
CUDDALORE - 607 002.
Cell: 9367620365.

FORM - C

1. Location of the building
(Door No, street Name
& Name of the Place) : ***V.C.S. Shemford International School***
(Run by Veechidambaranar Educational Trust)
R.S.No: 5/8,5/9,5/11 & 6/1, Vellakarai Road,
Vettukulam Village, Cuddalore Taluk & District.
2. Age of the Building : *17 years*
3. Number of Storeys : *Two Storied*
4. Short description of structures,
Steel R.C.C. Framed or load
bearing masonry : *R.C.C Roof framed Structure*
5. Purpose for which the building
certified for use : *Class rooms, Office, Staff room, Computer room,
Library And Toilet*
6. The period for which the building
will be structurally sound : *03.08.2026 to 02.08.2029*
7. Number of persons to be
Accommodated : *500 Nos*
8. Remarks : *Nil*

Date: ***01.08.2026***


Signature of the Engineer

Er. P. SIVAKUMAR, B.E.,M.I.E.,F.I.V.,
REGISTERED ENGINEER,
CLASS-IA (Under Tamil Nadu Public Building Act)
Reg. No: B1/18287/2017
No: 80, Lawrence Road,
CUDDALORE - 607 002.
Cell: 9367620365.

FORM - E

(Form of report to be made to the competent authority by inspecting authorities or officers appointed under other acts under Sec.28 of the Madras public Building (Licensing) Act 1965 (Madras Act 13 of 1965) referred to in rule 7 of the Madras public Building (Licensing) Rules 1966.)

1. Name and designation of the inspecting authority or officer appointed by or having jurisdiction under any other act or law : **Er.P.SIVAKUMAR,B.E, M.Sc(Valuation), M.I.E,F.I.V,**
*Chartered Engineer (INDIA),
Class -IA Panel Registered Engineer*
2. Location of the building
(Door No, street Name of the Place) : **V.C.S. Shemford International School**
*(Run by Veechidambaranar Educational Trust)
R.S.No: 5/8,5/9,5/11 & 6/1, Vellakarai Road,
Vettukulam Village, Cuddalore Taluk & District.*
3. Date of inspection : **01.08.2026**
4. Purpose for which the building certified for use : *Class rooms, Office, Staff room, Computer room,
Library And Toilet*
5. Nature of defects noticed : *No defects found*
6. Suggestion for rectifying defects : *Does not arise*
7. If in a dangerous condition immediate steps recommended to be taken : *Does not arise*

Date : **01.08.2026**


Signature of the inspecting authority
officer appointed / having jurisdiction

Er. P. SIVAKUMAR, B.E.,M.I.E.,F.I.V.,
REGISTERED ENGINEER,
CLASS-IA (Under Tamil Nadu Public Building Act)
Reg. No: B1/18287/2017
No: 80, Lawrence Road,
CUDDALORE - 607 002.
Cell: 9367620365.

DECLARATION

I P.SIVAKUMAR, residing at 80, Lawrence road, Cuddalore-2, do hereby declare that I possess the qualification and experience specified in the table rule II of the Tamil Nadu Public Buildings (Licensing) rule 1956 for issuing the certification of structural soundness of building covered by the certificates.

Place : Cuddalore

Date : **01.08.2026**

Signature of the Certifying engineer,

Er. P. SIVAKUMAR, B.E., M.I.E., F.I.V.,
REGISTERED ENGINEER,
CLASS-IA (Under Tamil Nadu Public Building Act)
Reg. No: B1/18287/2017
No: 80, Lawrence Road,
CUDDALORE - 607 002.
Cell: 9367620365.

1. Name and address (in block letters) : **Er.P.SIVAKUMAR**
80, Lawrence Road,
Cuddalore -607 002.
2. Engineering qualification : **B.E., (Civil & Structural), M.Sc (Valuation) M.I.E., F.IV.**
3. Enclosures :
1) Annexure enclosed
2) Photo copies
3) Building plan copy

Proceedings of the District Collector Cuddalore
Present: Thiru.V.Anbusekaran, IAS.

61/18287/2017

Dated: 31.12.2018

- Sub: Buildings – Tamilnadu Public Buildings (Licensing) Act 1965 –
Inclusion of Thiru.P.Sivakumar in the panel of private
practicing Registered Engineers Under Class 1A Category
Order issued-Regarding.
- Ref: 1. Application of Thiru.Sivakumar of Cuddalore
dated: 24.11.2017.
2. The Superintending Engineer, PWD Buildings (C&M)
Circle, Vellore No.D3/F.20, P.E 2018/30/m)
dated: 22.06.2018.
3. Engineer –in-Chief (WRD), and chief Engineer (General),
PWD, Chepatuk, Chennai. Lr.No.AEE/T1/AE-
2/39660/2018, dated: 31.10.2018.

Order:

Kind attention is invited to the reference cited.

The name of Thiru.P.Sivakumar B.E., Chartered Engineer, No.80, Lawrence Road, Cuddalore - 607002, is included in the panel of Private Registered Engineers, as laid down under class 1A (monetary limit of Rs.50/- lakhs and above) after getting approval of Board of Engineers, Chennai as per G.O.Ms.No.43, Municipal Administration and water supply (MA4) Department, Dated: 17.02.2011 for the issue of structural Soundness Certificate for Public Buildings under the Tamil Nadu Public Buildings (Licensing) Act 1965.

Hence, He is registered under the category of class-1A Engineer (Buildings cost of which exceeds Rs.50.00 lakhs) in Cuddalore district.

Sd/V.Anbusekaran,
District Collector,
Cuddalore.

/t.c.b.o/

[Signature] 31/12/2018
Personal Assistant (General) to Collector,
Cuddalore.

✓

Thiru.P.Sivakumar,
No.80, Lawrence Road,
Cuddalore - 607002

Copy for:

1. Commissioner of Revenue Administration,
Chepatuk, Chennai.
2. All Tahsildars of Cuddalore District.
3. B1 Stock file.